

Park Walk / Link.
Primary Link to Residential areas via north - south Links and Distributor Rd.
Lighting Subject to CCC Requirements



All dimensions in metres.
Do not scale from drawing.
For any discrepancies found please consult with design office.
This drawing should be read in conjunction with all contract drawings, documents and specifications.

All dimensions in metres.
Do not scale from drawing.
For any discrepancies found please consult with design office.
This drawing should be read in conjunction with all contract drawings, documents and specifications.

Proposed Philips Luma Gen2
A Mini_BGP703_DW50_11.5km on 8m lighting columns.

- | | | |
|---|---|--|
|  | A | Proposed Phillips Luna Gen2
Mini_BGP703_DW50_11.5km on 8m lighting columns. |
|  | C | Proposed Phillips Luna Gen2
Mini_BGP703_DW50_9.5km on 8m lighting columns. |
|  | D | Proposed Phillips Luna Gen2
Micro_BGP702_DW50_4.0km on 6m lighting columns. |
|  | E | Proposed Phillips Luna Gen2
Micro_BGP702_DX10_3.4km on 6m lighting columns. |
|  | F | Proposed Phillips Luna Gen2
Nano_BGP701_DRN1_0.8km on 6m lighting columns |
|  | | Proposed Phillips Luna Gen2
Nano_BGP701_DRN0_0.8km on 6m lighting columns |

Please see Public Lighting Design Report for full details on lanterns, column heights, tilt etc.

Public Lighting Design complies with BS5489 & EN13201.

Public Lighting Design complies with BS5489 & EN13201.

Columns shall be manufactured to BS EN 40-3-1:2013

Columns are to have a double locked flamed door and should

All columns to have duct chamber with cover at base.

1. **Ability** (ignoring to be read 11 will new power supply connections).

All Lanterns are to be Warm White 2700°K with a peak wavelength greater than 550nm.

No trees shall be planted within 7.5m of lighting columns on the same side of the road or in such a manner that the foliage is likely to obstruct the light in the future.

No trees shall be planted within 7.5m of lighting columns on the same side of the road or in such a manner that the foliage is likely to obstruct the light in the future.

The minimum clearance from edge of carriageway to face of lighting columns shall be 0.8m as per Table 2 from BS 5489 for a design speed of <50km/hr.

Hinged columns to be installed where accessibility by a maintenance vehicle is not viable.

GRID 1: SPINE ROAD MIDDLE - C4
GRID 2: SPINE ROAD CONFLICT ZONE 1 - C3
GRID 3: SPINE ROAD CONFLICT ZONE 2 - C3
GRID 4: SPINE ROAD CONFLICT ZONE 3 - C3
GRID 5: SPINE ROAD CONFLICT ZONE 4 - C3
GRID 6: SPINE ROAD BOTTOM - C4
GRID 7: N7 ESTATE ROADS P4
GRID 8: APARTMENT BLOCKS - P4

GRID 1: SPINE ROAD MIDDLE - C4
GRID 2: SPINE ROAD CONFLICT ZONE 1 - C3
GRID 3: SPINE ROAD CONFLICT ZONE 2 - C3
GRID 4: SPINE ROAD CONFLICT ZONE 3 - C3
GRID 5: SPINE ROAD CONFLICT ZONE 4 - C3
GRID 6: SPINE ROAD BOTTOM - C4
GRID 7: N7 ESTATE ROADS P4
GRID 8: APARTMENT BLOCKS - P4

The information on this drawing is confidential and must not be disclosed to any third party or reproduced, in whole or part, without the express written consent of MHL & Associates Ltd. All drawings remain the property of MHL & Associates Ltd. National Mapping Division of Tallie Etireann. All rights reserved. Licence number CV AL 50552843

The information on this drawing is confidential and must not be disclosed to any third party or reproduced, in whole or part, without the express written consent of MHL & Associates Ltd. All drawings remain the property of MHL & Associates Ltd. National Mapping Division of Tallie Etireann. All rights reserved. Licence number CV AL 50552843

Rev	By	Date	Description
-----	----	------	-------------

02	FOS	18/06/26	Revised as per design team comments
----	-----	----------	-------------------------------------

—
□
△
△
△
△
△
(

—
□
△
△
△
△
△
(

Project Title: _____


Longview Estates - Neighbourhood 7

Drawing Title:

Public Lighting Layout (2 of 2)

Clients

LONGVIEW



M.H.L. & Associates Ltd.
Consulting Engineers

Carragee Mor House,
10 High Street,
Douglas Road,
Cork

Tel: 021-4840214
Fax: 021-4840215
E-Mail: info@mhl.ie

Designed:	FOS	Drawn:	FOS	Checked:	KM
Scale:	1/500@A1	Date:	June 2026		
Job No:	24083HD	Drawing No:	24083HD-N7PL-P02	Revision:	02